

DataLink

Instruction CIPUCMMWrite

Lecture de la variable **NJ1_DataOUT1** appartenant au jeu de Tag **NJ1_DataOUT** dans la variable **NX1_DataIN1**



Node Address	Device	Description
192.168.250.14	Built-in EtherNet/IP Port Settings	NX1P2

Connection

Connections/Max: 1 / 32

Target Device	Connection Name	Connection I/O	Input/Output	Target Variable	Size [Byte]	Originator Variable	Size [Byte]
192.168.250.1 NJ101 Rev 2	default_001	Input Only (Tag)	Input	NJ1_DataOUT	2	NX1_DataIN	2

Global Variables X

Name	Data Type	Network Publish
NX1_DataOUT1	INT	Output
NX1_DataIN1	INT	Input

Tag Sets

Tag Sets/Max: 1 / 32 Tags/Max: 1 / 256


Tag Set Name	Bit	Size (Byte)	Size (Bit)	Instance ID	Controller Status
NX1_DataIN	<input type="checkbox"/>	2		Auto	Not included
NX1_DataIN1	<input type="checkbox"/>	2	0		

Global Variables X

Name	Data Type	Network Publish
NJ1_DataIN1	INT	Input
NJ1_DataOUT1	INT	Output



Ecriture de la variable **NX1_DataOUT1** dans la variable **NJ1_DataIN1** du **NJ1**



WriteData

CIPUCMMWrite

Execute	RoutePath	Busy	Busy
Done	UINT#1 TimeOut	Error	Err
	'NJ1_DataIN1' DstDat	ErrorID	ErrID
	UINT#1 Size	ErrorIDEx	ErrIDEx
	NX1_DataOUT1 SrcDat		

