

Function Block



OMRON ELECTRONICS S.A.S.
14 Rue de Lisbonne
93561 Rosny-sous-Bois cedex

N° Indigo 0 825 825 679
0.15€ TTC/mm

Référence	MTCP_ETN Client
Révision	2.3
Auteur	JP Viskovic
Date	11/01/2018
+ Support	http://support-omron.fr/

Function Block Modbus TCP Client dedicated to ETN21 Unit n°0

Function	Modbus TCP client for CS/CJ1W-ETN21 Unit N°0																																				
Connexion	<div style="border: 1px solid black; padding: 5px; width: fit-content; margin: auto;"> <p style="text-align: center;">MTCP_ETN_Connect</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">(BOOL) EN</td> <td style="width: 50%;">(BOOL) ENO</td> </tr> <tr> <td>(UINT) IP_Address1</td> <td>(BOOL) Error</td> </tr> <tr> <td>(UINT) IP_Address2</td> <td>(WORD) Error Code</td> </tr> <tr> <td>(UINT) IP_Adresse</td> <td>(BOOL) Waiting_Server</td> </tr> <tr> <td>(UINT) IP_Address4</td> <td></td> </tr> <tr> <td>(BOOL) Connect</td> <td></td> </tr> </table> </div>			(BOOL) EN	(BOOL) ENO	(UINT) IP_Address1	(BOOL) Error	(UINT) IP_Address2	(WORD) Error Code	(UINT) IP_Adresse	(BOOL) Waiting_Server	(UINT) IP_Address4		(BOOL) Connect																							
(BOOL) EN	(BOOL) ENO																																				
(UINT) IP_Address1	(BOOL) Error																																				
(UINT) IP_Address2	(WORD) Error Code																																				
(UINT) IP_Adresse	(BOOL) Waiting_Server																																				
(UINT) IP_Address4																																					
(BOOL) Connect																																					
Read/write Fn	<div style="border: 1px solid black; padding: 5px; width: fit-content; margin: auto;"> <p style="text-align: center;">MTCP_ETN_Fn01</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">(BOOL) EN</td> <td style="width: 50%;">(BOOL) ENO</td> </tr> <tr> <td>(UINT) Coil_Address</td> <td>(UINT) Rcv_Counter</td> </tr> <tr> <td>(UINT) Coil_Qty</td> <td>(BOOL) Error</td> </tr> <tr> <td>(UINT) RespData_DM</td> <td>(INT) Error_Code</td> </tr> <tr> <td>(BOOL) Cmd_Read</td> <td></td> </tr> <tr> <td>(WORD) Slaveld</td> <td></td> </tr> </table> </div>	(BOOL) EN	(BOOL) ENO	(UINT) Coil_Address	(UINT) Rcv_Counter	(UINT) Coil_Qty	(BOOL) Error	(UINT) RespData_DM	(INT) Error_Code	(BOOL) Cmd_Read		(WORD) Slaveld		<div style="border: 1px solid black; padding: 5px; width: fit-content; margin: auto;"> <p style="text-align: center;">MTCP_ETN_Fn03</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">(BOOL) EN</td> <td style="width: 50%;">(BOOL) ENO</td> </tr> <tr> <td>(UINT) Register_Address</td> <td>(UINT) Rcv_Counter</td> </tr> <tr> <td>(UINT) Register_Qty</td> <td>(BOOL) Error</td> </tr> <tr> <td>(UINT) RespData_DM</td> <td>(INT) Error_Code</td> </tr> <tr> <td>(BOOL) Cmd_Read</td> <td></td> </tr> <tr> <td>(WORD) Slaveld</td> <td></td> </tr> </table> </div>	(BOOL) EN	(BOOL) ENO	(UINT) Register_Address	(UINT) Rcv_Counter	(UINT) Register_Qty	(BOOL) Error	(UINT) RespData_DM	(INT) Error_Code	(BOOL) Cmd_Read		(WORD) Slaveld		<div style="border: 1px solid black; padding: 5px; width: fit-content; margin: auto;"> <p style="text-align: center;">MTCP_ETN_Fn05</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">(BOOL) EN</td> <td style="width: 50%;">(BOOL) ENO</td> </tr> <tr> <td>(UINT) Coil_Address</td> <td>(UINT) Rcv_Counter</td> </tr> <tr> <td>(UINT) Value</td> <td>(BOOL) Error</td> </tr> <tr> <td>(BOOL) Cmd_Write</td> <td>(INT) Error_Code</td> </tr> <tr> <td>(WORD) Slaveld</td> <td></td> </tr> </table> </div>	(BOOL) EN	(BOOL) ENO	(UINT) Coil_Address	(UINT) Rcv_Counter	(UINT) Value	(BOOL) Error	(BOOL) Cmd_Write	(INT) Error_Code	(WORD) Slaveld	
(BOOL) EN	(BOOL) ENO																																				
(UINT) Coil_Address	(UINT) Rcv_Counter																																				
(UINT) Coil_Qty	(BOOL) Error																																				
(UINT) RespData_DM	(INT) Error_Code																																				
(BOOL) Cmd_Read																																					
(WORD) Slaveld																																					
(BOOL) EN	(BOOL) ENO																																				
(UINT) Register_Address	(UINT) Rcv_Counter																																				
(UINT) Register_Qty	(BOOL) Error																																				
(UINT) RespData_DM	(INT) Error_Code																																				
(BOOL) Cmd_Read																																					
(WORD) Slaveld																																					
(BOOL) EN	(BOOL) ENO																																				
(UINT) Coil_Address	(UINT) Rcv_Counter																																				
(UINT) Value	(BOOL) Error																																				
(BOOL) Cmd_Write	(INT) Error_Code																																				
(WORD) Slaveld																																					
	<div style="border: 1px solid black; padding: 5px; width: fit-content; margin: auto;"> <p style="text-align: center;">MTCP_ETN_Fn06</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">(BOOL) EN</td> <td style="width: 50%;">(BOOL) ENO</td> </tr> <tr> <td>(UINT) Register_Address</td> <td>(UINT) Rcv_Counter</td> </tr> <tr> <td>(UINT) Value</td> <td>(BOOL) Error</td> </tr> <tr> <td>(BOOL) Cmd_Write</td> <td>(INT) Error_Code</td> </tr> <tr> <td>(WORD) Slaveld</td> <td></td> </tr> </table> </div>	(BOOL) EN	(BOOL) ENO	(UINT) Register_Address	(UINT) Rcv_Counter	(UINT) Value	(BOOL) Error	(BOOL) Cmd_Write	(INT) Error_Code	(WORD) Slaveld		<div style="border: 1px solid black; padding: 5px; width: fit-content; margin: auto;"> <p style="text-align: center;">MTCP_ETN_Fn0F</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">(BOOL) EN</td> <td style="width: 50%;">(BOOL) ENO</td> </tr> <tr> <td>(UINT) Coil_Address</td> <td>(UINT) Rcv_Counter</td> </tr> <tr> <td>(UINT) Coil_Qty</td> <td>(BOOL) Error</td> </tr> <tr> <td>(WORD) Dataddress_DM</td> <td>(INT) Error_Code</td> </tr> <tr> <td>(BOOL) Cmd_Write</td> <td></td> </tr> <tr> <td>(WORD) Slaveld</td> <td></td> </tr> </table> </div>	(BOOL) EN	(BOOL) ENO	(UINT) Coil_Address	(UINT) Rcv_Counter	(UINT) Coil_Qty	(BOOL) Error	(WORD) Dataddress_DM	(INT) Error_Code	(BOOL) Cmd_Write		(WORD) Slaveld		<div style="border: 1px solid black; padding: 5px; width: fit-content; margin: auto;"> <p style="text-align: center;">MTCP_ETN_Fn10</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">(BOOL) EN</td> <td style="width: 50%;">(BOOL) ENO</td> </tr> <tr> <td>(UINT) Register_Address</td> <td>(UINT) Rcv_Counter</td> </tr> <tr> <td>(UINT) Register_Qty</td> <td>(BOOL) Error</td> </tr> <tr> <td>(WORD) Dataddress_DM</td> <td>(INT) Error_Code</td> </tr> <tr> <td>(BOOL) Cmd_Write</td> <td></td> </tr> <tr> <td>(WORD) Slaveld</td> <td></td> </tr> </table> </div>	(BOOL) EN	(BOOL) ENO	(UINT) Register_Address	(UINT) Rcv_Counter	(UINT) Register_Qty	(BOOL) Error	(WORD) Dataddress_DM	(INT) Error_Code	(BOOL) Cmd_Write		(WORD) Slaveld	
(BOOL) EN	(BOOL) ENO																																				
(UINT) Register_Address	(UINT) Rcv_Counter																																				
(UINT) Value	(BOOL) Error																																				
(BOOL) Cmd_Write	(INT) Error_Code																																				
(WORD) Slaveld																																					
(BOOL) EN	(BOOL) ENO																																				
(UINT) Coil_Address	(UINT) Rcv_Counter																																				
(UINT) Coil_Qty	(BOOL) Error																																				
(WORD) Dataddress_DM	(INT) Error_Code																																				
(BOOL) Cmd_Write																																					
(WORD) Slaveld																																					
(BOOL) EN	(BOOL) ENO																																				
(UINT) Register_Address	(UINT) Rcv_Counter																																				
(UINT) Register_Qty	(BOOL) Error																																				
(WORD) Dataddress_DM	(INT) Error_Code																																				
(BOOL) Cmd_Write																																					
(WORD) Slaveld																																					
File	MTCP_ETN_Client.zip																																				
PLC	- CJ1xx-V3 + CJ1W-ETN21 et CJ2H/M + CJ1W-ETN21 - CS1xx + CS1W-ETN21																																				
Restriction of use	The ETN21 unit should be set to No 0 The FB use socket n° 1 and TCP Port number 502																																				

Conditions of use	<p>The FB Modbus TCP Client provides some read/write features in accordance with the specifications defined by the Modbus organization.</p> <p>The Modbus TCP Client function block is offered 'as is' and may serve as a basis for development.</p> <p>Users should previously test its adequacy to the final application.</p> <p>Omron could not be held responsible in case of malfunction.</p>																																															
Principe	<p>The function block MTCP_ETN_Connect establish the connection with a remote Modbus TCP server when Connect input is activated.</p> <p>ENO output could allow execution of read/write FB via the EN input.</p> <p>List of read/write functions provided :</p> <table border="1"> <thead> <tr> <th>Code</th> <th>Modbus Function</th> <th>Function Block</th> </tr> </thead> <tbody> <tr> <td>0x01</td> <td>Read coils</td> <td>MTCP_ETN_Fn01</td> </tr> <tr> <td>0x02</td> <td>Read Input Status</td> <td>MTCP_ETN_Fn02</td> </tr> <tr> <td>0x03</td> <td>Read Holding Registers</td> <td>MTCP_ETN_Fn03</td> </tr> <tr> <td>0x04</td> <td>Read Input Registers</td> <td>MTCP_ETN_Fn04</td> </tr> <tr> <td>0x05</td> <td>Write Single Coil</td> <td>MTCP_ETN_Fn05</td> </tr> <tr> <td>0x06</td> <td>Write Single Register</td> <td>MTCP_ETN_Fn06</td> </tr> <tr> <td>0x0F</td> <td>Write Multiple Coils</td> <td>MTCP_ETN_Fn0F</td> </tr> <tr> <td>0x10</td> <td>Write Multiple Registers</td> <td>MTCP_ETN_Fn10</td> </tr> <tr> <td>0x17</td> <td>Read Write Multiple Registers</td> <td>MTCP_Client_Fn17</td> </tr> </tbody> </table> <p>Memory Area used by the FB</p> <table border="1"> <thead> <tr> <th>Type</th> <th>address</th> <th>Descriptions</th> </tr> </thead> <tbody> <tr> <td>send</td> <td>D32500-D32506</td> <td>Zone de consignation de la requête</td> </tr> <tr> <td>receive</td> <td>D32510-D32642</td> <td>Zone de réception de la réponse</td> </tr> </tbody> </table> <p>Flags and commands related to ETN21 unit n° 0</p> <table border="1"> <thead> <tr> <th>Type</th> <th>address</th> <th>Descriptions</th> </tr> </thead> <tbody> <tr> <td>Flags/command</td> <td>CIO1500 - CIO1524</td> <td rowspan="2">More détails : Socket Service de W421</td> </tr> <tr> <td>Parameters</td> <td>D 30000 - D30099</td> </tr> </tbody> </table>	Code	Modbus Function	Function Block	0x01	Read coils	MTCP_ETN_Fn01	0x02	Read Input Status	MTCP_ETN_Fn02	0x03	Read Holding Registers	MTCP_ETN_Fn03	0x04	Read Input Registers	MTCP_ETN_Fn04	0x05	Write Single Coil	MTCP_ETN_Fn05	0x06	Write Single Register	MTCP_ETN_Fn06	0x0F	Write Multiple Coils	MTCP_ETN_Fn0F	0x10	Write Multiple Registers	MTCP_ETN_Fn10	0x17	Read Write Multiple Registers	MTCP_Client_Fn17	Type	address	Descriptions	send	D32500-D32506	Zone de consignation de la requête	receive	D32510-D32642	Zone de réception de la réponse	Type	address	Descriptions	Flags/command	CIO1500 - CIO1524	More détails : Socket Service de W421	Parameters	D 30000 - D30099
Code	Modbus Function	Function Block																																														
0x01	Read coils	MTCP_ETN_Fn01																																														
0x02	Read Input Status	MTCP_ETN_Fn02																																														
0x03	Read Holding Registers	MTCP_ETN_Fn03																																														
0x04	Read Input Registers	MTCP_ETN_Fn04																																														
0x05	Write Single Coil	MTCP_ETN_Fn05																																														
0x06	Write Single Register	MTCP_ETN_Fn06																																														
0x0F	Write Multiple Coils	MTCP_ETN_Fn0F																																														
0x10	Write Multiple Registers	MTCP_ETN_Fn10																																														
0x17	Read Write Multiple Registers	MTCP_Client_Fn17																																														
Type	address	Descriptions																																														
send	D32500-D32506	Zone de consignation de la requête																																														
receive	D32510-D32642	Zone de réception de la réponse																																														
Type	address	Descriptions																																														
Flags/command	CIO1500 - CIO1524	More détails : Socket Service de W421																																														
Parameters	D 30000 - D30099																																															

1- I/O variable of MTCP_ETN_Connect

Input Variables

Name	type	range	Description
EN	Bool	OFF, ON	FB Activation
IP_Address1	UINT	00 - FF	IP Address of the server (byte 1,2,3,4)
IP_Address2			
IP_Address3			
IP_Address4			
Connect	Bool	OFF, ON	Request to connect to the server
Waiting_Server	Bool	OFF, ON	ON: waiting for the synchronization from the server

Output Variables

Name	type	Range	Description
ENO	Bool	OFF, ON	ON : Connected to the server
Error	Bool	OFF, ON	Error flag
Error_Code	UINT	0 - FFFF	Error Code returned by the socket switch or Modbus TCP server (see error code list below).

2- Input Variables of FB MTCP_ETN_Fn01, Fn03, Fn05, Fn06, Fn0F , Fn10 and Fn17

MTCP_ETN_Fn01 MTCP_ETN_Fn02	type	range	Description
EN	Bool	OFF, ON	FB Activation (ENO of FB Connect)
Coil_Address	UINT	0 - FFFF	Address of 1rst coil
Coil_Qty	UINT	0 - 00FF	Number of coils
RespData_DM	UINT	0 - FFFF	Destination of data (DM area)
Cmd_Read	Bool	OFF, ON	Read Command
SlaveID	Word	0- 255	Slave number (00=FF by default)

MTCP_ETN_Fn03 MTCP_ETN_Fn04	type	range	Description
EN	Bool	OFF, ON	FB Activation (ENO of FB Connect)
Register_Address	UINT	0 - FFFF	Address of 1rst register
Register_Qty	UINT	0 - 00FF	Number of registers
RespData_DM	UINT	0 - FFFF	Destination of data (DM area)
Cmd_Read	Bool	OFF, ON	Read Command
SlaveID	Word	0- 255	Slave number (00=FF by default)

MTCP_ETN_Fn05	type	range	Description
EN	Bool	OFF, ON	FB Activation (ENO of FB Connect)
Coil_Address	UINT	0 - FFFF	Address of the coil
Value	Bool	OFF, ON	ON/OFF value to be written
Cmd_Write	Bool	OFF, ON	Write command
SlaveID	Word	0- 255	Slave number (00=FF by default)

MTCP_ETN_Fn06	type	range	Description
EN	Bool	OFF, ON	FB Activation (ENO of FB Connect)
Register_Address	UINT	0 - FFFF	Address of the register
Value	UINT	0 - FFFF	Value to write
Cmd_Write	Bool	OFF, ON	Write command
SlaveID	Word	0- 255	Slave number (00=FF by default)

MTCP_ETN_Fn0F	type	range	Description
EN	Bool	OFF, ON	FB Activation (ENO of FB Connect)
Coil_Address	UINT	0 - FFFF	Address of 1rst coil
Coil_Qty	UINT	0 - 00FF	Number of coil to write
DataAddress_DM	UINT	0 - FFFF	Source of data (DM area)
Cmd_Write	Bool	OFF, ON	Read Command
SlaveID	Word	0- 255	Slave number (00=FF by default)

MTCP_ETN_Fn10	type	range	Description
EN	Bool	OFF, ON	FB Activation (ENO of FB Connect)
Register_Address	UINT	0 - FFFF	Address of 1rst register
Register_Qty	UINT	0 - 00FF	Number of registers
DataAddress_DM	UINT	0 - FFFF	Source of data (DM area)

Cmd_Write	Bool	OFF, ON	Write command
SlaveID	Word	0- 255	Slave number (00=FF by default)

MTCP_CP1L_Fn17	type	range	Description
EN	Bool	OFF, ON	FB Activation (use ENO of FB Connect)
UNIT_ID	UINT	00 - FF	Unit Identifier (0 = default value -> &255)
Timeout	UINT	0 - FFFF	Timeout in 0.1s (0 : default value = 100ms)
Reg_Address_Read	UINT	0 - FFFF	Address of 1rst register
Reg_Qty_Read	UINT	0 - 00FF	Number of registers
RespData_DM	UINT	0 - FFFF	Destination of data (DM area)
Reg_Address_Write	UINT	0 - FFFF	Address of 1rst register
Reg_Qty_Write	UINT	0 - 00FF	Number of registers
Data_Adress_DM	UINT	0 - FFFF	Source of data (DM area)
Cmd_Send	Bool	OFF, ON	Send the ReadWrite Command

3- Output Variables of FB MTCP_ETN_Fn01, Fn03, Fn05, Fn06, Fn0F et Fn10

Name	type	Range	Description
ENO	Bool	OFF, ON	ON : Server Connected
Rcv_Counter	UINT	0 - FFFF	Reception counter
Error	Bool	OFF, ON	Execution error flag
Error_Code	UINT	0 - FFFF	Error Code returned by the socket switch or Modbus TCP server (see error code list below).

Error Code returned by the Modbus TCP server (Modbus exception response)

Code	Description
0001	ILLEGAL FUNCTION
0002	ILLEGAL DATA ADDRESS
0003	ILLEGAL DATA VALUE

Error Code returned by the TCP Socket switch OpenActive, Send and Receive

2607	Socket already in use
0302	CPU Unit error: cannot execute
1100	Number bytes to send/receive not in allowed range
1101	The area designation of the Send/Receive Data address is not in allowable range
1103	The bit number in the Send/Receive data address is not in allowable range
110C	Request switch turned ON during other processing
220F	Specified socket is already processing a SEND request
2210	The specified socket is not connected
2211	Unit is busy: cannot execute
2606	Specified socket is already open as UDP socket
2607	Specified socket service parameter area is already being used by another socket
0020	Connection with remote socket broken during Send (EPIPE)
003E	Internal buffer cannot be obtained due to high reception traffic
0045	Error in communication with remote node
004B	Error communication with remote node (again)
004E	Remote IP address parameter error (ET unreach)
0051	Remote IP address parameter error (Host unreach)
0053	Error communication with remote HOST
0080	Receive request Timed out
0081	Specified socket was closed during receive processing

ANNEXE

Modbus protocol

I/O memory area (CIO) Read Multiple Coils

Example: read 19 bits (CIO 0001.04 to 0002.06)

Request		Response	
	Data		Data
Function Code	0x01	Function Code	0x01
Starting Address(H)	0x00	Byte Count	0x03
Starting Address(L)	0x14	Coil Status 27-20	0xCD
Quantity of Coils(H)	0x00	Coil Status 35-28	0x6B
Quantity of Coils(L)	0x13	Coil Status 38-36	0x05

	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
0CH	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
1CH	<i>31₁</i>	<i>30₀</i>	<i>29₁</i>	<i>28₁</i>	<i>27₁</i>	<i>26₁</i>	<i>25₀</i>	<i>24₀</i>	<i>23₁</i>	<i>22₁</i>	<i>21₀</i>	<i>20₁</i>	19	18	17	16
2CH	47	46	45	44	43	42	41	40	39	<i>38₁</i>	<i>37₀</i>	<i>36₁</i>	<i>35₀</i>	<i>34₁</i>	<i>33₁</i>	<i>32₀</i>
3CH	63	62	61	60	59	58	57	56	55	54	53	52	51	50	49	48

Italic characters show the ON/OFF(1/0) status of its bit condition.

Reads registers in I/O memory area

Example: read 3 words (DM 1000 to DM 1002)

Request		Response	
	Data		Data
Function Code	0x03	Function Code	0x03
Starting Address(H)	0x03	Byte Count	0x06
Starting Address(L)	0xE8	Register Value(H)DM1000	0xAB
Quantity of Registers(H)	0x00	Register Value(L) DM1000	0x12
Quantity of Registers(L)	0x03	Register Value(H)DM1001	0x56
		Register Value(L) DM1001	0x78
		Register Value(H)DM1002	0x97
		Register Value(L) DM1002	0x13

DM	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
1000	A				B				1				2			
1001	5				6				7				8			
1002	9				7				1				3			

Writes single coil.

Example: write 1 coil. (CIO 0002.02 ON)

Request		Response	
	Data		Data
Function Code	0x05	Function Code	0x05
Output Address(H)	0x00	Output Address(H)	0x00
Output Address(L)	0x22	Output Address(L)	0x22
Output Value(H)	0xFF	Output Value(H)	0xFF
Output Value(L)	0x00	Output Value(L)	0x00

	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
0CH	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
1CH	31 ₁	30 ₀	29 ₁	28 ₁	27 ₁	26 ₁	25 ₀	24 ₀	23 ₁	22 ₁	21 ₀	20 ₁	19	18	17	16
2CH	47	46	45	44	43	42	41	40	39	38 ₁	37 ₀	36 ₁	35 ₀	34 ₁	33 ₁	32 ₀
3CH	63	62	61	60	59	58	57	56	55	54	53	52	51	50	49	48

*Italic characters show the ON/OFF(1/0) status of its bit condition.***Writes single register.**

Example: write &h3AC5 to DM 2000.

Request		Response	
	Data		Data
Function Code	0x06	Function Code	0x06
Register Address(H)	0x07	Register Address(H)	0x07
Register Address(L)	0xD0	Register Address(L)	0xD0
Register Value(H)	0x3A	Register Value(H)	0x3A
Register Value(L)	0xC5	Register Value(L)	0xC5

DM	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
2000	3			A				C			5					
2001																
2002																

Writes registers.

Example: write 2 words into DM1000-1001.

Request		Response	
	Data		Data
Function Code	0x10	Function Code	0x10
Starting Address(H)	0x03	Starting Address(H)	0x03
Starting Address(L)	0xE8	Starting Address(L)	0xE8
Quantity of Registers(H)	0x00	Quantity of Registers(H)	0x00
Quantity of Registers(L)	0x02	Quantity of Registers(L)	0x02
Byte Count	0x04		
Registers Value(H)	0x3A		
Registers Value(L)	0xC5		
Registers Value(H)	0x97		
Registers Value(L)	0x13		

DM	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
1000	3			A				C			5					
1001	9			7				1			3					

Writes Multiple coils.

Example: In the case of writing 10 bits (xxxx xx11 1100 1101) to CIO 0001.04.

(X = ignored.)

Request		Response	
	Data		Data
Function Code	0x0F	Function Code	0x0F
Starting Address(H)	0x00	Starting Address(H)	0x00
Starting Address(L)	0x13	Starting Address(L)	0x13
Quantity of Outputs(H)	0x00	Quantity of Outputs(H)	0x00
Quantity of Outputs(L)	0x0A	Quantity of Outputs(L)	0x0A
Byte Count	0x02		
Output Value(H)	0x3A		
Output Value(L)	0x01		

	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
0CH	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
1CH	31 ₀	30 ₀	29 ₀	28 ₁	27 ₀	26 ₀	25 ₁	24 ₁	23 ₁	22 ₀	21 ₁	20 ₀	19 ₀	18 ₀	17 ₀	16 ₀

Italic characters show the ON/OFF(1/0) status of its bit condition.

Read and Write multiple registers Fn17

Example: read registers 1 & 2 (1001-2002) and write CAFE into register 0003.

Requête		Réponse	
	Donnée		Donnée
Function Code	0x17	Fonction Code	0x17
Starting Address(H) to read	0x00	Nbre of byte	0x04
Starting Address(L) to read	0x01	Valeur du registre 1 (poids faible)	0x10
Quantity of Registers(H) to read	0x00	Valeur du registre 1 (poids fort)	0x01
Quantity of Registers(L) to read	0x02	Valeur du registre 2 (poids faible)	0x20
Starting Address(H) to write	0x00	Valeur du registre 2 (poids fort)	0x02
Starting Address(L) to write	0x03		
Nbre of registers (H) to write	0x00		
Nbre of registers (L) to write	0x01		
Nbre of byted'octets à écrire	0x02		
1ère valeur (poids fort)	0xCA		
1ère valeur (poids faible)	0xFE		

	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
0000			3				A				C				5	
0001			1				0				0				1	
0002			2				0				0				2	
0003			C				A				F				E	